

# RCR&A

## RICHARD C. RINKS & ASSOCIATES, INC.

Engineering and Architectural Services

Building Enclosure Consultants

ASCE - NSPE - TSPE - IIBEC - EDI

30 North Jefferson Avenue - P.O. Box 691 - Cookeville, Tennessee 38503-0691  
Telephone 931-528-5543 Rinks-Consulting.com Facsimile 931-528-5544

**ADDENDUM 1  
NEW HALL NORTH ROOF REPLACEMENT  
TENNESSEE TECHNOLOGICAL UNIVERSITY  
COOKEVILLE, TENNESSEE  
SBC NO. 364/011-07-2022  
FEBRUARY 9, 2024**

1. See attached Clarifications.
2. Contractor shall acknowledge receipt of this addendum on Bid Form.

END OF ADDENDUM

Attachment: Clarifications

\\ttu-23\addendum1.doc



**CLARIFICATIONS  
NEW HALL NORTH ROOF REPLACEMENT  
TENNESSEE TECHNOLOGICAL UNIVERSITY  
COOKEVILLE, TENNESSEE  
SBC NO. 364/011-07-2022  
FEBRUARY 9, 2024**

Q: Please provide elevations plans that reference the “new 24-ga prefinished kynar 500 metal counterflashing” in the details on 4/D1 and 5/D1, so that quantities can be determined.

**A: These details are referenced on Sheet R2. Recommend you visit the site to look at the roof.**

Q: Is there a Number of days to completion?

**A: This is shown on the Plans and Specs.**

Q: Please provide the measurements for copper pipe boots – Detail 3/ R2-D1: base, length x width, cap, inner diameter and outer diameter of pipe with copper sleeve, hooks, hook length x flange length (made from copper bar stock? Stainless?) and copper pipe sleeve, height

**A: The base can be a minimum of 12”x12” or larger if required. The other dimensions will need to be verified by the contractor in the field. Hooks shall be copper.**

Q: Can you provide clarification on the hatch ladder that needs to be replaced? I assume this is the ladder we used to access the roof. What is the need for replacement and do you have a spec for the replacement ladder?

**A: The Plans call for a new ladder up, which attaches to the existing ladder. See Section 08 50 00 in Specs.**